

Relation between code no. 352 electric power facilities as causal agents and type of Fatal and non-fatal accidents in 1999-2020

code	Type of accident	1999	2000	2001	2002	2003	2004	2005	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020	total
01	fall from height		1	1				3	1		1	1	2			1	1	1	1	2		1	18	
02	falling to same level					2		2	2	1	2	1		1	1			2		3	1	2		20
03	crash		2	1				1		2	2	2	3	2	2	5	1		4		1	1	4	33
04	struck by flying or falling object		1	2		1			2	3		3	4	3	4	1	2		1	1	2	2	3	35
05	collapse		1			1		3	3	1		3	1		4				1	1	2	2		23
06	crashed by		2			1			1	1	1		3			2	3		2	1			2	19
07	caught in/between		3	4		1		3	3	2		3		2	2	1	2	5	8	2		7	1	49
08	cut		1						2	2					2		1		1					10
09	injury to the sole of the foot																							
10	drown																							
11	contact to high/low-temperature		11	19		17		9	7	20	19	10	17	12	14	7	13	10	10	11	14	4	9	233
12	contact to harmful substance										1				1				1	1				4
13	electric shock		39	45		37		39	28	38	37	27	37	26	25	30	33	27	13	20	33	17	24	575
14	explosion		1			1		1			1	1				2	2							9
15	burst							2						2			1							5
16	fire		1					1			1		1	1	1	1	1	1	1		2	1		12
17	traffic accident (public road)																	1		1				2
18	traffic accident (others)																							
19	reaction to motion/improper motion		1	1		3		1	1	2	1		4	1					2		1	1	1	20
90	others																					1		1
99	unclassifiable																							
00	total		64	73		64		65	50	72	66	51	72	50	56	49	60	47	45	42	59	38	45	1,068

Data of 2011 year include Industrial accidents caused by Great East Japan Earthquake in 2011.

Data sources: <https://anzeninfo.mhlw.go.jp/user/anzen/tok/anst00.htm> (MHLW, Japan)

Return to <https://www.jisha.or.jp/english/statistics/2020enfctcs.html>